



FONTANA FIRE PROTECTION DISTRICT FIRE PREVENTION



SUBMITTAL CHECKLIST NFPA 17 – DRY CHEMICAL EXTINGUISHING SYSTEMS

GENERAL:	CONTR	FIRE
1) A minimum of three complete sets of drawings		
2) Completed application		
3) Payment		
4) Copy of contractor license		
DRAWINGS MUST SHOW THE FOLLOWING TO BE ACCEPTED:	CONTR	FIRE
5) Building/ project name		
6) Building/ project street address and city		
7) Contractor name, address, license number and phone number		
8) Scaled or fully dimensional drawing		
9) Equipment symbol legend		
10) Sectional view of room		
11) Total number of all electrical devices		
12) Detector and nozzle location and description		
13) The amount of dry chemical		
14) The size, length and arrangement of connected piping, or piping and hose		
15) Information to identify the apparatus and devices used		
16) Point to point system wiring diagram		
17) Type and gauge of wire or cable		
18) Riser diagram		
19) Identify zones, circuits and end-of-line resistor locations		
ADDITIONAL INFORMATION REQUIRED:	CONTR	FIRE
Specification sheets		
Battery calculation sheet		
CO2 system design information		

NOTES: