



FONTANA FIRE PROTECTION DISTRICT FIRE PREVENTION



SUBMITTAL CHECKLIST NFPA 14 – STANDPIPE & HOSE SYSTEMS

GENERAL:		CONTR	FIRE
1) A minimum of three sets of drawings			
2) Completed application			
3) Payment			
4) Copy of contractor license			
5) System Components are listed for intended use, specification information sheets are provided. Non-listed items can be tanks or pumps			
DRAWINGS MUST SHOW THE FOLLOWING TO BE ACCEPTED:		CONTR	FIRE
6) Owner / project name			
7) Project, street address and city			
8) Building or suite number if applicable			
9) Contractor name, address, phone number and license number			
10) Scaled or fully dimensional plans			
11) Point of compass			
12) Description of hazard			
13) Elevation diagram			
14) Equipment legend per NFPA 720			
15) Occupancy class			
16) Class of standpipe system			
17) Plot plan showing supply piping and pipe size from the water source to the building			
18) Building dimensions, height and the location of the fire department connection (FDC)			
19) Valve details and locations			
IF WAREHOUSE, DRAWINGS MUST INCLUDE THE FOLLOWING TO BE ACCEPTED:		CONTR	FIRE
20) PRV			
21) Every other fire department access door			
22) Standpipe plumbed from adjoining system			
23) Calculations to prove 250 GPM			
24) Hydrant blue dot adjacent to door where standpipe is located			
ADDITIONAL INFORMATION REQUIRED:		CONTR	FIRE
25) Three sets of hydraulic calculations with summary, detail worksheets and graph sheet			
26) Flow report dated within one year of submittal date on water department letterhead or department form			
27) Detailed cut sheets and specification sheets for all equipment			

NOTES: