



FONTANA FIRE PROTECTION DISTRICT FIRE PREVENTION



SUBMITTAL CHECKLIST

CFC SECT. 309, CH. 27 & NFPA 505 (CHARGING STATION)

CFC SECT. 608 & CH. 27 (STATIONARY BATTERY SYSTEM EG: UPS FOR COMP. SYSTEM)

GENERAL:	CONTR	FIRE
1) A minimum of three sets of drawings.		
2) Completed application		
3) Payment		
4) Copy of contractor license		
DRAWINGS MUST SHOW THE FOLLOWING TO BE ACCEPTED:	CONTR	FIRE
5) Building/ project name		
6) Building/ project street address and city		
8) Contractor name, address, license number and phone number		
9) Scale or fully dimensional drawing including building floor plan		
10) Equipment symbol legend		
11) Designated area free of combustibles		
12) Electrolyte spill control		
13) Type of batteries (recombinant or non-recombinant). Include number and quantity electrolyte per battery. Battery to charger ratio.		
14) Fire extinguisher minimum 4A20-B:C rated		
15) Protection against physical damage		
16) Adequate ventilation – 6 air exchange per hour		
17) Equipment necessary for handling a battery		
18) Electrical installations per CFC		
19) Signage to indicate no smoking or open flame		
20) HMMP if > 55 gallons of electrolyte at stationary location		
ADDITIONAL INFORMATION REQUIRED:	CONTR	FIRE
21) Quantity of electrolyte in excess of exempt amount may require construction of control area.		

NOTES: