



FONTANA FIRE PROTECTION DISTRICT FIRE PREVENTION



SUBMITTAL CHECKLIST CFC 34 – ABOVEGROUND STORAGE TANKS AND PIPING

GENERAL:	CONTR	FIRE
1) A minimum of three sets of drawings		
2) Completed application		
3) Payment		
4) Copy of contractor license		
DRAWINGS MUST SHOW THE FOLLOWING TO BE ACCEPTED:	CONTR	FIRE
6) Owner / project name		
7) Project, street address and city		
8) Building number or other identification		
9) Contractor's name, address, phone number and license number		
10) Scaled or fully dimensional plans		
11) Point of compass		
12) Show UL 2085 or 142		
13) Scaled site plan showing room, room dimensions, equipment placement or location in relation to building, streets, property lines or other public ways		
14) Gallon capacity of tank		
15) Overflow prevention alarm		
16) Emergency shutoff switch		
17) Minimum 20B fire extinguisher		
18) Impact protection		
19) Appropriate signage		
ADDITIONAL INFORMATION REQUIRED:	CONTR	FIRE
20) Manufacture data sheets or cut sheets on tank and equipment		

NOTES: